



NATIONAL
ENVIRONMENTAL
TESTING, INC.

AUG 31 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

08/24/1998

NET Job Number: 98.05666
Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to NET, Inc. Indianapolis Division for analysis:

Project Description: TWICE WEEKLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
215761	OUTFALL 001	08/13/1998	08/14/1998

National Environmental Testing, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.

Project Representative

MIL0004690



NATIONAL
ENVIRONMENTAL
TESTING, INC.

AUG 31 1998

Indianapolis Division
6964 Hillside Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

08/24/1998

Job No.: 98.05666
Page 2 of 3

Date Received: 08/14/1998

Job Description: TWICE WEEKLY WASTEWATER

Sample Number / Sample I.D.			Sample Date/ Units	Analyst & Date Analyzed	Method	Reporting Limit
Parameters	Result	Flag				
215761	OUTFALL 001		08/13/1998			
Iron, ICP	0.79		mg/L	tjg / 08/22/1998	EPA 200.7	<0.10
Lead, ICP	<0.080		mg/L	tjg / 08/22/1998	EPA 200.7	<0.080
Silver, ICP	<0.020		mg/L	tjg / 08/22/1998	EPA 200.7	<0.020
Zinc, ICP	0.095		mg/L	tjg / 08/22/1998	EPA 200.7	<0.020

MIL0004691



NATIONAL
ENVIRONMENTAL
TESTING, INC.

AUG 31 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

FIELD REPORT

JOB # 98.05666
CLIENT: MILBANK MANUFACTURING INC
PROJECT: TWICE WEEKLY WASTEWATER
DATE: 08/14/98
SAMPLER(S): MEM

An ISCO model 3710 auto sampler was used in the composite mode of operation. The sampler was equipped with a plastic composite jug, tygon suction line, battery, and strainer.

All reusable equipment is decontaminated with alconox, tap water, 5% nitric acid, and deionized water. New tygon suction tubing was used for the sampler. A stainless steel strainer was also used for the sampling event.

The sampler was set to take a sample every 30 minutes for 8 hours.

Monitoring start 7:30 on 08/13/98
Monitoring end 15:00 on 08/13/98

The composite sample was clear.

Notes: Samples were preserved, in the field, in the appropriate containers with required preservatives.

MIL0004692



COMPANY Milbank Mann Juring
ADDRESS 1400 East Havens St. Kokomo, IN 56901-3188
PHONE 765-452-5694 FAX _____
PROJECT NAME/LOCATION 2x weekly wastewater
PROJECT NUMBER _____
PROJECT MANAGER _____

REPORT TO: MR. H d Tyler

INVOICE TO: _____

P.O. NO. _____

NET QUOTE NO. 98.0060

AUG 31 1978

SAMPLED BY
Michael E. Milliken
(PRINT NAME)

(PRINT NAME)

MS Milka
SIGNATURE

SIGNATURE

ANALYSES

To assist us in selecting the proper method

Is this work being conducted for regulatory compliance monitoring? Yes _____ No _____

Is this work being conducted for regulatory enforcement action? Yes _____ No _____

Which regulations apply: RCRA _____ NPDES Wastewater _____
UST _____ Drinking Water _____
Other _____ None _____

COMMENTS

* metals (Fe, Pb, Ag, Zn)

[illegible]

CONDITION OF SAMPLE: BOTTLES INTACT? YES / NO
~~FIELD FILTERED? YES / NO~~ N/A

~~COC SEALS PRESENT AND INTACT? YES / NO~~
~~VOLATILES FREE OF HEADSPACE? YES / NO~~ N/A

TEMPERATURE UPON RECEIPT: _____
Bottles supplied by NET? ~~YES~~ NO

SAMPLE REMAINDER DISPOSAL: RETURN SAMPLE REMAINDER TO CLIENT VIA _____
I REQUEST NET TO DISPOSE OF ALL SAMPLE REMAINDERS _____

DATE _____

RELINQUISHED BY: ME Miller

METHOD OF SHIPMENT

DATE	TIME
8/14/78	1550

RECEIVED BY:

RELINQUISHED BY:

DATE
8/24/98

TIME
15:45

RECEIVED FOR NET BY:

REMARKS: